



## California Regional Water Quality Control Board, San Diego Region

June 13, 2014

Mr. John T. Reilly President SeaWorld San Diego 500 SeaWorld Drive San Diego, CA 92109

In reply refer to: CIWQS Place ID: 256121:MMata

Subject: Review of Self-Monitoring Report for Order No. R9-2011-0032, NPDES No. CA0107336, SeaWorld San Diego

Mr. Reilly:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has completed review of the January – March 2014 monthly reports and January – March 2014 quarterly report for the subject facility. During our review, the following violation was noted:

## **Effluent Violation**

The effluent exceeded the 30-day limitation for total coliform of no more than 10 percent of the samples collected during any calendar month should exceed 230/100 mL for a five-tube test. Approximately 29% of the samples exceeded 230/100mL during the month of March at the east treatment facility.

Please take steps to ensure that violations such as the one noted above do not occur in the future. Pursuant to the California Water Code, violations may result in enforcement by the San Diego Water Board, including issuance of an enforcement order and/or financial penalties.

In the subject line of any response, please include the reference number "CIWQS Place ID: 256121: MMata." For questions or comments, please contact Michelle Mata by phone at (619) 521-3369, or by email MMata@waterboards.ca.gov.

1/

Respectfully

Brandi N. Qutwin-Beals, P.E.

Senior Water Resources Control Engineer

Source Control Unit

- 2 -

BNO:mm

Tech Staff Info & Use	
Order No.	R9-2011-0032
Party ID	40319
WDID	9 000000083
NPDES No.	CA0107336
Reg. Measure ID	133368
Place ID	256121
Person ID	388530
Violation ID	967995